



YELLOW ALERT!

DOSH/OSHA Recordable

Date: July 2008

Re: OSHA Recordable

The following DOSH/OSHA Recordable has occurred. In an effort to prevent similar injuries from occurring at your location, please review the injury summary shown below. Remember that a Supervisor's Incident Report is to be completed and faxed to ERNWest, within 24 hours of notification of the incident. Every accident/incident will be investigated regardless of the extent of injuries. Even a near miss or minor injury can give you causes that may stop a more serious accident from occurring in the future. Your experienced based recommendations and ideas for prevention of such an accident are welcomed and **needed**.

I. Injury Summary:

Date Of Injury:	June 26 th , 2008
Date Reported:	June 26 th , 2008
Injury Type:	Electric Shock to Both Hands
Injury Cause:	Employee was working on ladder working on electrical wire. Employee had the breaker switched off and was wiring a neutral wire to a new circuit. Affected breakers were not shut off at panel. As employee was wiring the neutral wires he received an 110V shock to both hands. Employee fell off 3ft ladder injuring his back and hands. It was later discovered that the neutral wires were shared resulting in the injury. Employee went to hospital and was given medications for his back and burn cream for his hands.
Action Taken to Prevent Reoccurrence:	Employee should have shut off all breakers in the box using company lockout-tagout procedures. Employee should have also used a glow-stick to check and see if wire was charged.