



# YELLOW ALERT!

## ***DOSH/OSHA Recordable***

**Date:** September 2010

**Re:** OSHA Recordable

The following DOSH/OSHA Recordable has occurred. In an effort to prevent similar injuries from occurring at your location, please review the injury summary shown below. Remember that a Supervisor's Incident Report is to be completed and faxed to ERNWest, within 24 hours of notification of the incident. Every accident/incident will be investigated regardless of the extent of injuries. Even a near miss or minor injury can give you causes that may stop a more serious accident from occurring in the future. Your experienced based recommendations and ideas for prevention of such an accident are welcomed and **needed**.

**I. Injury Summary:**

<b>Date Of Injury:</b>	August 5, 2010
<b>Date Reported:</b>	August 5, 2010
<b>Injury Type:</b>	Electrocution
<b>Injury Cause:</b>	Employee (electrician helper) was cutting wrong conduit with live wire inside. Employee received an electric shock with no permanent injuries.
<b>Action Taken to Prevent Reoccurrence:</b>	The accident investigation revealed the employee did not follow instructions from the senior electrician and cut the wrong conduit. Both employees were counseled. This accident could have been very tragic.